Document downloaded from:

http://hdl.handle.net/10251/202511

This paper must be cited as:

Alfonso-Solar, D.; Perpiñá, C.; Pérez-Navarro, A.; Peñalvo-López, E.; Vargas-Salgado, C.; Cárdenas, R. (2009). Methodology for optimization of distributed biomass resources evaluation, management and final energy use. Biomass and Bioenergy. 33(8):1070-1079. https://doi.org/10.1016/j.biombioe.2009.04.002



The final publication is available at

https://doi.org/10.1016/j.biombioe.2009.04.002

Copyright Elsevier

Additional Information

# Methodology for optimization of distributed biomass resources evaluation, management and final energy use

2 3 4

1

D. Alfonso \*, C. Perpiñá, A. Pérez-Navarro, E. Peñalvo, C. Vargas, R. Cárdenas

5 6 7

Instituto de Ingeniería Energética, Universidad Politécnica de Valencia Camino de Vera s/n Edificio 8E, bloque F, 46022 Valencia, SPAIN

8 9

10

11

12

13

14

15

16

17

#### **Abstract**

A methodology has been developed to assess optimal management and energy use of distributed biomass resources, where logistics is a main factor but other features must be also considered: biomass resources properties (quantity, quality, seasonality & availability), plant size effect, available technologies for power, heat and solid biofuels generation, CO<sub>2</sub> emissions balance and quantification of potential biofuel consumers.

This methodology provides a quantification and characterization of biomass resources, a list of optimal locations from logistic point of view and the necessary data to perform detailed technical, economic and environmental analysis of the different biomass energy use options. It has been applied to three districts of the Valencian region in Spain and main results and conclusions are also included in this paper.

18 19 20

Biomass resources, optimization methodology, biomass transport, distributed energy resources.

21 22 23

24

25

26

27

28

29

 $\overline{30}$ 

31

32

33

34

#### 1. Introduction

The massive implementation of distributed energy resources is a key element for the strategy to increase energy efficiency and reliability of supply. Biomass is a renewable energy source which implies large savings in harmful emissions to the atmosphere taking advantage of local energy resources in a sustainable way. Nowadays the energy use of biomass in Spain is very limited but climate and intense agricultural activities should provide a higher contribution of this renewable source in the total needs of primary energy. The planned rapid deployment of biomass installations requires the development of a general methodology to identify the best biomass applications for each geographical area that guarantee its technical, economical, environmental viability, and reliability of supply to the final consumers of processed biofuels, electricity or heat. This methodology should provide detailed evaluation of biomass resources, potential biofuel (pellets, wood chips) demand for thermal or cogeneration applications, optimization of biomass management (collecting and transport) costs and emissions, and best available energy valorisation technologies (pre-treatment technologies as pellet production, and generations technologies for combined heat and power generation)

35 36

39

## 2. Methodology

37 38

The methodology can analyse wide geographic areas by making subdivision and considering a potential biomass plant in each subdivision. Subdivision size can obey to administrative boundaries (default

40 option), customer defined groups of municipalities or other specific criteria (i.e.: upper limit for transport 41 distance).

next paragraphs the global approach and the different modules are described.

The developed methodology has been structured in six different modules as described in Figure 1. In the

44

45

42 43

> Corresponding author. Address: Instituto de Ingeniería Energética, Universidad Politécnica de Valencia, Camino de Vera s/n, edificio 8E, bloque F, planta 2, 46022 - Valencia, SPAIN. Phone: +34 963877270; Fax: +34 963877272, e-mail: daalso@die.upv.es




Figure 1: Scheme of methodology to assess the optimal energy valorisation of biomass resources

Specially for biomass resources module and logistic module using geographic information systems (GIS) is an adequate tool [1,2]. GIS can be employed as an strategic planning tool or as an operational tool, in this last case, where it is requested finer spatial resolution (i.e. transport distance or time calculations), GIS becomes an indispensable tool.

The application of the methodology will provide an accurate knowledge of biomass resources and will optimize:

- Locations of the biomass plant from the point of view of logistics (minimum transport times).
- Energy application. In these centres biomass can be converted into electricity, heat and /or standardized biofuels (pellets), according to local energy demand, biomass resources characterization and other possible additional constraints (i.e. legislation), which favour possible applications. Methodology should clarify which application to address.
- Employed technology. Selected energy application (i.e. power plant, cogeneration plant...) can be performed using different technologies (boiler + steam turbine, gasifier + internal combustion engine,...), but biomass properties and plant size combine with technology restrictions (maximum or minimum size, maximum ash content, ...) will provide which technologies to use.

Final application and technology selection will be given by the optimization criteria, which can obey to economic or environmental issues (CO<sub>2</sub> balance), and the imposed restrictions of the possible scenario.

#### 2.1 Biomass resources module

1 2

 Biomass sources considered in the analysis are those derived from forestry, agricultural crops (woody crops as olives, grapes, oranges, almonds, apples,...; and herbaceous crops as rice, wheat, barley, maize...) and agro-industries (olive oil industries, wine production industries, dry fruits peeling plants, rice mills,...). Quantification of biomass resources is performed using generation ratios as those described in Table 1. These generation ratios and characterization of produced waste biomass (higher heating value, moisture and ash content) have been obtained from bibliography [3 – 8] and direct field analysis during BIOVAL project (BIOVAL is a project titled "Optimization of the Energy Use of Biomass Resources in the Valencian Region", 2005 – 2006, funded by the regional government of the Valencian region – IMPIVA, Generalitat Valenciana- and the European Fund of Regional Development). Regarding the generation ratios, in most cases standard deviations were in the range 20 – 50%.

Table 1.
Biomass resources quantification. Generation ratios for agricultural residues


Code	Biomass resource (type of crop)	Description	Waste generation ratio (referred to wet bi		HHV (MJ·kg <sup>-1</sup> dry)	Moisture (% wet basis, fresh)	<b>Ash</b> (%dry basis)
$AG_{Ai}$	Agricultural residues from woody crops	Annual tree prunings	1.8-4.1 (t·year <sup>-1</sup> · l cropland)	nm <sup>-2</sup> of	17.2-18.4	30 – 40 %	1.8-3.4 %
$AG_{Bi}$	Agricultural residues from herbaceous crops	Cereal straw, maize cobs and stalks	1.5-7.8 (t·year <sup>-1</sup> · h cropland)	nm <sup>-2</sup> of	16.8-18.1	20 – 30 % ª	4.2-7.5% <sup>b</sup>

$FR_{\rm i}$	Forestry residues	Silviculture waste	1.0 - 1.9( t·year <sup>-1</sup> · hm <sup>-2</sup> of woodland)	18 – 20%	29 – 45%	1.2 – 3.4%
$AI_i$	Agro-industrial residues	Fruit peels and pulp, cereal husk, dry fruit	0.16 - 3.6 (t·t <sup>-1</sup> of product)	16 – 22.0%	$50-65\%^{c}$	$2-6\%^{\rm d}$

<sup>&</sup>lt;sup>a</sup> fresh Maize cobs and stalks have a moisture content of 55-65%

Geographic location of biomass residues can be performed using GIS with a resolution of 1-km<sup>2</sup> pixel or using municipalities as minimum area units.

Seasonality is also an important factor for logistics, specially for agricultural residues where it can be very severe. It can be evaluated in a monthly basis according to typical labour operations during year for each crop (for agricultural wastes) and typical production cycles for industries. In Figure 2 (a) it has been included typical seasonality functions for several agricultural crops (tree prunings and cereal straw), these functions are applicable when it is considered more than one cultivation plot of each representative crop, because they can be considered as statistical functions so it is required a minimum sample size to be meaningful. In Figure 2 (b) it has been included the aggregated seasonality analysis of a district, obtained as the addition of mass of each type of agricultural waste biomass every month.






Figure 2: Seasonality graphics of agricultural waste biomass. (a) Single crops, (b) Aggregated seasonality for districts In this module the availability for energy use of each type of agricultural waste biomass (availability coefficients) is defined according to bibliography [5,6] and additional surveys performed by the authors, being important to take into account other uses of biomass (i.e. animal feeding, domestic fuel), and size of

b rice straw has an ash content (in %dry basis) of around 18%

<sup>&</sup>lt;sup>c</sup> dry fruits shells and rice husk have low moisture content in the range 8-12% (in % wet basis)

d rice husk has an ash content (in %dry basis) of around 17%

agricultural plots. In Table 2 in has been included a summary of availability considerations. For agricultural waste biomass global availability was in the range 20 - 40% referred to the total theoretical biomass production.

#### Table 2.

#### Biomass resources availability for energy use.

Biomass resource	Availability for energy use	Additional considerations	
Tree prunings (AG <sub>Ai</sub> )	60 – 80%	It was considered that biomass from plots smaller than a minimum value $(0.6-0.8~\mathrm{hm^2})$ would not be collected due to	
Cereal straw & similar $(AG_{Bi})$	15 – 30% (rice straw & corn stalks 50 -60%)	difficult accessibility and logistics (for the same total area, many small plots instead of few big ones provide higher management complexity)	
Forestry (FR <sub>i</sub> )	20 – 40%	This percentage represents the waste biomass produced due to silviculture treatments really performed in Spain compared with the theoretical potential value computed according to woodland surface.	

## 

#### 2.2 Demand module

Suitable demand segments or typical customers for thermal or cogeneration applications with biomass must be identified (hospitals, schools, residential homes, industries,...) and, according to statistical and cartographic data, these demand points or areas are located in the map (mainly urban areas and industrial areas) and quantified in terms of energy needs (kWh·year-1). Three different demand sectors: residential (R), commercial (C) and industrial (I) have been considered.

Suitable demand segments of commercial and residential sector are, mainly, those included in the European directive about energy performance of buildings [9], focused on increasing energy use efficiency and renewables (solar, biomass,...). In these segments main energy needs can be potentially covered by a central boiler for hot water, space heating and cooling (with absorption systems). They are included in Table 3.

In the industrial sector the suitable demand segments have been identified using reports from EUBIONET [6,7] and project Pellets for Europe [10]. In these segments the energy needs are steam, hot water or hot air for drying.

Average thermal energy needs for each demand segment has been estimated using Spanish national statistics and official sectorial reports from the Spanish administration and defining a thermal energy indicator which employs statistical data available for each demand segment (n. of beds, total area, n. of students, turnover,...) as detailed in Table 3.

Table 3. Estimation of potential demand for local consumption of biofuels

Sector	Demand Segments	<u>Thermal energy</u> consumption indicator (for hot water, steam or other suitable thermal process)
	School	400 − 500 kWh·student <sup>-1</sup> · year <sup>-1</sup>
	Sport activities	400 - 500 kWh·user <sup>-1</sup> · year <sup>-1</sup>
С	Hospital	25 - 35 MWh·bed <sup>-1</sup> · year <sup>-1</sup>
	Care centres	$40 - 110 \text{ kWh} \cdot \text{m}^{-2} \cdot \text{year}^{-1}$
	Hotels	25 - 35 MWh·room <sup>-1</sup> · year <sup>-1</sup>
R	Residential homes	$40-110~kWh/m^2\cdot$ year, considering 5 climatic zones in Spain for houses of $~80-130~m^2$ and $3-4$ people.
		200 – 1700 kWh· (k€_turnover) <sup>-1</sup> · year <sup>-1</sup>
I	Industry	$40 - 480 \text{ MWh} \cdot \text{employee}^{-1} \cdot \text{year}^{-1}$
		Different values according to specific industrial activity based on NACE <sup>a</sup> code.

a NACE Code is a pan-European classification system which groups organisations according to their business activities. It assigns a unique 5 or 6 digit code to each industry sector. Examples of these codes are NACE code DA.15.50 (Manufacture of dairy products) or DB.17.30 (Finishing of textiles)

After considering the total thermal energy demand of each sector it must be considered the fraction of available market for biomass applications, given the fact that a percentage of the customers will employ other fuels or electricity to cover their thermal needs. It has been considered, as default values, that the available market for biomass applications is 10% for the residential sector, 30 % for commercial sector, and 30% for industrial sector.

Grouping of these segments can be made according to administrative boundaries (municipalities or districts). Typically, small/medium customers (school, small hospitals, houses...) require high quality biofuels (low ash, sodium, chlorine and sulphur content) for thermal applications (central boilers), and large customers (i.e. industries) can use lower quality biofuels for both thermal or cogeneration applications, as they are usually able to deal with ash disposal, gas cleaning and maintenance requirements.

#### 2.3 Logistic module

9

10 11

12

13

14

15

16

17 18

19

20

21

22

23

24

25

26

 $\overline{27}$ 

28

29

Based on road network characteristics and accessibility to biomass sources, this module allows computing transport time and distances between two generic points x (origin) and y (destination) in the area of study, these functions are called Time(x,y) and Distance(x,y). Sources or origins of biomass are fixed and destination can be either fixed by the restrictions of the considered scenario (i.e. presence of power plants, hospitals, industrial customer, etc.) or by applying an algorithm of minimization of transport costs (according to transport time or distance), which is the most usual approach to define optimum location of the biomass plant for a considered area. This module provides the biomass transport including specific considerations about logistic structure (maximum weight of transport unit and previous densifications in bales, if any). Typically, a biomass transport cost function [2], is composed by fixed costs and distance dependent costs. The evaluation of average biomass transport cost, ABTC (€·t<sup>-1</sup>), of a specific potential location (y=y<sub>B</sub>) for a biomass plant is given by the following equations:

$$BTC(x,y) = \frac{FC + DC \cdot Distance(x,y)}{TUC}$$
 (1)

$$FC=FC1+FC2$$
 (2)

$$DC=DC1+DC2$$
 (3)

33 
$$ABTC(x_{i}, y_{B}) = \frac{FC \cdot NR + DC \cdot \sum_{i} Distance(x_{i}, y_{B})}{TUC \cdot NR}$$
 (4)

35 where:

34

44

- 36 BTC(x,y) = the specific cost of a single run transporting biomass from point x to point y  $(\epsilon \cdot t^{-1})$
- 37 FC = the fixed cost due to loading/unloading (FC1), and compaction (FC2) operations
- 38 Distance(x,y) = one-way distance between point x and point y.
- 39 NR = the total number of runs
- 40 DC = distance dependent costs duel to fuel consumption and operation and maintenance (€·km<sup>-1</sup>) of the
- 41 transport unit (DC1, i.e. truck) and the baling system unit (DC2). This coefficient includes also time
- 42 dependent cost (hours of personnel) by considering an average transport speed of 30 – 50 km·h<sup>-1</sup>.
- 43 TUC = transport unit or truck capacity (in tonne)

45 Two logistic structures are available in the logistic module of the methodology at the moment which are 46 called BLS1 and BLS2. In BLS1 biomass is transported in medium size truck (truckload of 8 – 12 t, 25 -47 30 m<sup>3</sup>) with previous compaction of biomass (bales of around 1 m<sup>3</sup>, 300 – 400 kg). In BLS2 biomass is 48 transported also in the same medium size truck but without compaction, in this case truckload is fixed on 3 tonne. A summary of main considerations made in order to obtain the transport cost function for logistic structure BLS1 can be found in Table 4. These considerations are based on real experience of enterprises dealing with biomass collecting and transport in Spain, and machinery specifications from manufacturers.

Table 4.
Considered parameters and values for transport cost computing of logistic structure BLS1

Distance dependent costs for logistic structure BLS1

Parameter	DC1 <sup>a</sup>	DC2 <sup>a</sup>
Speed (km·h <sup>-1</sup> )	30 - 50	30 - 50
Fuel consumption (1/100km)	30	30
Maintenance (€·km <sup>-1</sup> )	0.1	0.1
Personnel (people)	1	2
DC - distance dependent cost (€·km <sup>-1</sup> )	1.5	0.525

Fixed cost estimation for logistic structure BLS1

Parameters	FC1 <sup>b</sup>	FC2b
Bales production capacity (t·h <sup>-1</sup> ) Fuel consumption for full load of transport	-	4
unit (l)	5	25
Transport unit capacity (tonne) Required time for full load of transport unit	10	10
(hours)	3	2.5
Personnel (number of workers))	1	2
Fixed cost (€ per run)	41.0	85.0

Reference cost indicator	Value	
Fuel (€·1-1)	1	
Personnel (€·h <sup>-1</sup> )	12	
Operation & Maintenance of vehicles		
(€·km <sup>-1</sup> )	0.1	

<sup>&</sup>lt;sup>a</sup> DC1 – Distance dependent cost of the transport unit (truck), DC2 – Distance dependent cost of the baling system unit.

Finally, Eq. (5) and Eq.(6) represent average biomass transport cost functions, ABTC, for logistic structure BLS1 and BLS2 respectivelly. It can be deduced that previous compaction provides a lower specific transport cost (in  $\mathfrak{E} \cdot \mathfrak{t}^{-1}$ ), even for short transport distances.

16 ABTC\_1(x<sub>i</sub>,y<sub>B</sub>) = 12.6 + 
$$\frac{0.2025}{NR}$$
· Distance(x<sub>i</sub>,y<sub>B</sub>), for BLS1 (5)

17 ABTC\_2(
$$x_i, y_B$$
) =13.7 +  $\frac{0.5}{NR} \cdot \sum_i Distance(x_i, y_B)$  , for BLS2 (6)

In a real biomass plant it is usual to partially or totally subcontract the transport activities, specially when biomass resources present severe seasonality. In this case it can be useful to estimate, separately, the cost of previous compaction ( $\cdot$ t-1) which will be present anyway. This cost function is given by Eq. (7):

22 
$$CPC(x,y)=8.5 + 0.0525 \cdot Distance(x,y)$$
 (7)

23 where

CPC(x,y) = the specific cost of compacting biomass ( $(\cdot, t^{-1})$ ) of point x for posterior transport to point y. It depends also on distance because compaction machine must move to the collecting point.

<sup>&</sup>lt;sup>b</sup> FC1 – Loading/unloading cost of the transport unit (truck), FC2 – Baling cost.

3 inv 4 par

There are additional costs associated to transport activities which are those derived from required investment to buy the necessary trucks and compaction machines. The cost and basic operation parameters of these vehicles are summarized in Table 5.

Table 5.

Cost and basic operation parameters for biomass transport and compaction vehicles.

Vehicle	Cost, k€/unit	Lifetime, years	Typical Operation	Capacity
Compaction truck	420	7	8 h/day, 230 d∙year <sup>-1</sup>	4 t·h-1 of bales
Transport truck	170	7	10 h/day, 230 d∙year <sup>-1</sup>	3 – 4 runs per day BLS1: 10 t/compacted load BLS2: 3 t/uncompacted load

In order to quantify the impact of logistic structure investment in the biomass transport process it can be obtained an additional transport cost derived from logistic structure (ATCLS, in  $\epsilon$  per tonne of biomass) considering the lifetime of the vehicles. For a biomass plant of 25000 t·year<sup>-1</sup> (wet) and an average transport distance of 20 km results are shown in Table 6

12 Ta

Impact of logistic structure investment on biomass transport cost transport cost

Logistic structure	Compa	ction truck	Transp	ort Truck	Biomass plant size	ATCLS
Logistic structure	Units	Total cost (k€)	Units	Total cost (k€)	t·year⁻¹ (wet)	€· t <sup>-1</sup>
BLS1	4	1.680	5	850	25000	14.5
BLS2	-	-	15	2550	25000	14.6

It is observed that ATCLS is similar for both logistic structures so it can be concluded that BLS1 (transport with previous compaction) should be selected as average biomass transport cost, already showed in Eq. (5), is lower. It is also interesting to note that for a defined biomass plant with an average transport distance of around 20 km, the average biomass transport cost (ABTC) and additional transport cost derived from logistic structure (ATCLS) are similar for BLS1 (in the range  $14 - 17 \ \mbox{e} \cdot \mbox{t}^{-1}$ ). When using BLS2 the ATCLS remains in the range  $14 - 15 \ \mbox{e} \cdot \mbox{t}^{-1}$  but the average biomass transport cost is higher  $(23 - 25 \ \mbox{e} \cdot \mbox{t}^{-1})$ .

#### 2.4 Technology characterisation module

Technologies for energy use of biomass are characterized in the methodology in terms of conversion efficiencies, cost and specific restrictions (i.e. minimum size, maximum ash content,...), and influence of plant size, defined through biomass consumption B ( $t \cdot h^{-1}$  of raw biomass), in these parameters.

This module also includes the characterization of pre-treatment plants (pellet production plants) and generation/cogenerations plants included in Table 7. These plants are characterized from an economic and efficiency point of view according to bibliography [3,4] and manufacturers by several functions: Installation cost, IC(B) (in  $\in$  per t·h<sup>-1</sup>), specific Operation and Maintenance costs of the whole plant, OMC(B), Electric and Thermal efficiency, EFF<sub>E</sub>(B) and EFF<sub>TH</sub>(B), respectively in MWh·t<sup>-1</sup>.

Table 7.

General description of bioenergy plants included in the technology characterization module

Bionergy plant		Efficien	cy (%HHV)	Restrictions	
Code	Description	Electric	Thermal	Application range, R_AP	Max. ash content %dry basis, R_ASH
BP1	Biomass pelletization plant (Dryer + grinder + pelletizer)	-	80-90%	> 10 kt·year-1 of pellets	1 - 6%
BP2	Biomass gasification power plant. Fluid	24 - 27%	31 - 37%	$>0.5~MW_e$	<5%

1
2
3
4
5
6
7

	bed gasifier with internal combustion engine. Thermal output can be hot water or low pressure steam (< 10 bar)				
BP3	Similar to BP2 but with downdraft fixed bed gasifier.	16 – 21%	25 – 30%	$0.05-0.8\;MW_e$	not specified
BP4	Biomass power plant based on ORC (organic rankine cycle) turbine. Thermal output is hot water at 80-90°C	15 - 17%	65 -72%	0.2 - 2 MW <sub>e</sub>	not specified
BP5	Biomass power plant based on condensing steam turbine.	15 -22%	-	$> 2 \; MW_e$	not specified

In figure 3 it is shown IC and OMC functions for a pellet production plant (BP1), and IC for a biomass gasification power plant based on fluid bed gasifier and internal combustion engine (BP2). For BP2 it is usually employed a constant value of OMC of around  $0.02 \in \text{kWh}^{-1}$  referred to generated electricity, equivalent to  $11 - 15 \in \text{t}^{-1}$  of wet biomass. In this example plant size is referred to wet biomass with a 40% of moisture. Regarding specific restrictions for the plant types BP1 and BP2 it must be taken into account that ash content should be lower than 3% and 5% respectively, to assure technical viability.




Figure 3: Biomass plant specific installation and O&M costs as a function of the plant size

#### 2.5 Environmental / CO<sub>2</sub> savings module

In this module the  $CO_2$  saving due to substitution of electricity produced in conventional power plants and/or thermal energy produced by consumption of fossil fuels are computed. In the global  $CO_2$  emissions balance it must be taken into account the use of fossil fuels in transport and collection (directly related to transport distances and compactation requirements), and biofuel productions process (pelletization). In order to compute  $CO_2$  savings and effective emission,  $CO_2$  emission factors from IPPC<sup>1</sup> European Directive and bibliography [13,14] have been used, Table 8 summarizes some of them.

Table 8. CO<sub>2</sub> emission factors of several energy carriers

	Emission factor		
Fuel or Electricity	Code	kgCO <sub>2</sub> ·kWh <sup>-1</sup> (HHV)	

 $<sup>^1</sup>$  Council Directive 96/61/EC of 24 September 1996 concerning integrated pollution prevention and control. Oficial. Journal L 257 , 10/10/1996 P. 0026-0040

Electricity – NG (combined cycle, 55% efficiency) power plants	CO2E01	0.33
Electricity - Oil power plants (38% efficiency)	CO2E02	0.68
Electricity - Coal power plants (38% efficiency)	CO2E03	0.87
Electricity - European power plants mix <sup>a</sup>		
(40% coal, 30% gas, 30% non fossil)	CO2E04	0.43
NG - fuel	CO2F01	0.18
Oil – fuel <sup>b</sup>	CO2F02	0.26
Coal - fuel	CO2F03	0.33
Fuel mix for thermal applications <sup>c</sup>		
(50% gas, 40% oil, 10% coal)	CO2TH01	0.23

<sup>&</sup>lt;sup>a</sup> Electricity distribution losses have not been included.

In a biomass power or cogeneration plants the  $CO_2$  savings are due to the electricity and thermal energy produced in the plant, which substitutes electricity from the grid ( $CO_2$  savings of 0.43 kg $CO_2 \cdot kWh^{-1}$ ) and thermal energy from boilers (0.28 kg $CO_2 \cdot kWh^{-1}$ ).

The production process of a pellet plant requires electricity (mainly for milling and pelletization) and heat (for drying) as showed in

Table 9, and these energy needs produce  $CO_2$  emissions. In a typical medium size pellet production plant [12,15] with a capacity of 2.86 t·h<sup>-1</sup> of pellets (with 10% of moisture content in wet basis), corresponding to 4.76 t·h<sup>-1</sup> of raw biomass, the emission factor, considering Electricity from European power plants mix, is  $0.02 \text{ kg}CO_2 \cdot \text{kWh}^{-1}$  of produced pellets (HHV basis).

Table 9.

Energy requirements of conventional pellet production plant on hourly basis.

Energy input, MW (HHV basis)		Energy output, MW (HHV basis)			
Raw Biomass	Electricity	Fuel <sup>a</sup>	Biomass pellets	Electricity	Heat
13,22	0,51	2,05	11,17	-	-

<sup>&</sup>lt;sup>a</sup> Assuming biomass pellets as fuel for drying purposes.

Raw biomass management (loading/unloading, compaction and transport) produces CO<sub>2</sub> emissions due to fuel consumption. Based on considerations made in the logistic module for cost estimation, it can be obtained average specific CO<sub>2</sub> emissions functions (ACO<sub>2</sub>) for biomass logistic structures BLS1 and BLS2 as described in Eq.(8) and Eq.(9) respectively. In these equations CO<sub>2</sub> emissions due to loading/unloading, compaction and transport operation are included (compaction only for BLS1).

ACO2\_1(x<sub>i</sub>,y<sub>B</sub>) = 8.4 + 
$$\frac{0.17}{NR} \cdot \sum_{i} Distance(x_{i},y_{B})$$
, for BLS1 (8)

27 ACO2\_2(x<sub>i</sub>,y<sub>B</sub>) = 4.7 + 
$$\frac{0.56}{NR}$$
·  $\sum_{i}$  Distance(x<sub>i</sub>,y<sub>B</sub>) , for BLS2 (9)

Looking at function ACO2(xi,yB) it is obtained that, for more than 7-9 km of average transport distance, BLS1 (transport with previous compaction) produces lower CO<sub>2</sub> emissions than BLS2 (without previous compaction).

#### 2.7 Computing and optimization module

This module interacts with the other modules to apply defined scenario constraints and optimization criteria which must be fulfilled in the optimization process. As showed in Table 5; Error! No se encuentra el origen de la referencia., scenario constraints can limit the type biomass to be taken into account, biomass collection and transport structure, specific type or types of bioenergy plant to be

<sup>&</sup>lt;sup>b</sup> Emission factor for Oil can be expressed as 2.8 kgCO<sub>2</sub>·l<sup>-1</sup>

<sup>&</sup>lt;sup>c</sup> To evaluate CO<sub>2</sub> savings due to thermal power from cogeneration applications it is included the HHV efficiency of the boiler (≈ 80% HHV), or other thermal system, which will be substituted by the heat recovery system of the cogeneration plant. The energy units are referred to kWh of net thermal energy.

- analysed, or the possible plant locations. Table 10 describes the applied constraints considered for the
- BIOPTION scenario applied to the Valencian region in the BIOVAL project, selected biomass resources,
- 1 2 3 biomass logistic structure, type of bioenergy plants to be analyzed and additional constraints were fixed
- 4 by the Valencian government according to regional short term objectives regarding biomass energy
- 5 resources use.

## Description of applicable constraints for a generic scenario in the methodology

Applicable constraint	Description	Considered values in scenario BIOPTION		
Biomass resources	It defines the sources of biomass that will be considered (AG <sub>Ai</sub> , AG <sub>Bi</sub> , FR <sub>i</sub> ,). Some scenarios can require analysing specific sources	Agricultural biomass, forestry and agro-industrial residues from olive oil industry:		
	of biomass because of environmental implications, legislation, high availability or other reasons.	$AG_{Ai}$ , $AG_{Bi}$ , $FR_i$ , $AIi$ (only residues from olive oil industry)		
Biomass logistic structure	It defines the selected logistic structure (BLS1, BLS2) to be analysed.	Transport with previous compaction: BLS1		
Bioenergy plants	It defines the types of bioenergy plants to be analysed (BP1, BP2,).	Pellet plant and generation/cogeneration plants: BP1 & BP2 & BP5		
Technology restrictions	It defines the technology restrictions to be applied as described in Table 7. These restrictions can be ignored in case it is considered future situations in which economic or technical features of a selected technology could change.	Regarding application range and maximum ash content of the raw biomass:  R_AP, R_ASH		
Additional constraints:	It allows additional constraints that are usually used in viability studies for biomass plants.  Typical examples are:  - To limit biomass transport distance by district boundaries and/or with a maximum transport distance (i.e. 25 km).  - To define the number of possible locations (5, 10, 20,), ordered and selected according to minimum transport costs, showed in the results.	Additional constraints: transport distance limited to district boundaries, minimum transport costs define 20 possible locations.		

- 8 Methodology application to the most employed scenarios includes an optimization in two steps: the first 9 one provides the list of the best locations according to minimum transport costs and biomass resources
- 10 distribution, and the second step is based on user criteria taking into account provided results about
- 11 potential local biomass consumers, average biomass properties and potential biomass plant
- 12
- characteristics (size, costs, efficiency and CO<sub>2</sub> savings).
- 13 The optimization process can be performed based on different criteria. In Table 6 it is included
- 14 description and assumptions for two optimization criteria.

## 15

#### 16 Optimization criteria. Description and assumptions.

Optimization criteria	Description & assumptions
Economic suitability	Minimum Simple Payback period of the installation (years)  - Energy prices: Electricity = 0.11 €·kWh <sup>-1</sup> , heat =0.025 €·kWh <sup>-1</sup> , pellet =150 €·t <sup>-1</sup> .  - Biomass logistic structure costs: 170 k€ per truck, 420 k€ percompaction machine - 40% of subcontracted transport & 130 € per subcontracted run  - For BP2 it is considered an O&M cost of 0.02 €·kWh <sup>-1</sup> of produced electricity and additional costs of personnel for general purposes of 2 people with an hourly cost of 20 €·h <sup>-1</sup> .
Maximum CO <sub>2</sub> savings	Minimum CO <sub>2</sub> emission of the global process (kg of CO <sub>2</sub> per t of processed biomass) BP1 = Pellet production for substitution of fossil fuels in thermal applications

BP2, BP3, BP4 = Cogeneration and electricity only applications

BP5 = only electricity applications

CO<sub>2</sub> savings reference:

- Electricity European power plants mix 0.43 kgCO<sub>2</sub>·kWh<sup>-1</sup>
- Cogeneration heat 0.28 kgCO<sub>2</sub>·kWh<sup>-1</sup> (referred to thermal energy)
- Fuel Fuel mix for thermal applications 0.23 kgCO<sub>2</sub>·kWh<sup>-1</sup> (HHV)

1 2

3


4 5

6 7 8

#### 3. Results and discussion

Figure 4 and Table 7. include main results of the methodology application to three districts of the Valencian region (C.V) under the scenario BIOPTION described in **¡Error! No se encuentra el origen de la referencia.** Figure 4 shows an example of the 20 best locations for one district and Table 12 describes quantity and main properties of biomass resources, potential local demand (biomass consumers), basic characteristics of potential biomass plants for the three districts, and economic and CO<sub>2</sub> savings analysis.

9



10 11

Figure 4. Optimal biomass plant locations for district 0326 -El Comtat.

1213

Table 7.

Main results of methodology application for three districts of C.V.

Identification and general results at district level				
District code - name	0326 - El Comtat	0327 - L'Alcoià	4623 - La Costera	
District total area, km <sup>2</sup>	377,8	539,7	528,3	
Biomass, kt·year-1	19.38	25.36	24.00	
Biomass, t·h <sup>-1</sup> - 5000 h·year <sup>-1</sup>	3,9	5,1	4,8	
Average LHV, kWh·kg <sup>-1</sup>	2,82	2,98	2,97	
Ash content, % dry basis	1,5%	2,6%	2,1%	
Mean transport distance, km	11,5	16,7	23,3	
Transport cost, €·t <sup>-1</sup>	16,9	17,2	18,5	
Local demand,				
% of self-consumed biomass	74%	68%	14%	
Potential cogeneration sites	11	7		
Application BP1. Pellet production plant				
Pellet production, kt·year-1	11.5	15.09	14.28	
Specific investment, k€·t⁻¹·h⁻¹	873	763	785	

Simple payback period_BP1, year	7,2	6,5	7,0	
CO <sub>2</sub> savings_BP1, kg CO <sub>2</sub> ·t <sup>-1</sup> of biomass	525	524	513	
Application BP2. Power plant – Fluid bed biomass gasifier with IC engine				
Rated power, MW - 5000 h·year-1	3,10	4,20	4,1	
Electric efficiency, %LHV	30,8%	31,7%	31,5%	
Specific investment, k€·kW <sup>-1</sup>	2.28	2.02	2.07	
Specific investment, M€·t <sup>-1</sup> ·h <sup>-1</sup>	1.82	1.67	1.71	
Simple payback period_BP2, year	9,9	8,5	8,9	
CO <sub>2</sub> savings_BP2, kg CO <sub>2</sub> · t <sup>-1</sup> of biomass	334	345	346	
Simple payback period_BP2 (+CHP), year	7,0	6,1	6,4	
CO <sub>2</sub> savings_BP2 (+CHP), kg CO <sub>2</sub> · t <sup>-1</sup> of biomass	602	623	612	

1 2

3

4

5

6

7

8

9

10

15

16

17 18

19

20

In these three districts both applications, pellet or power plant, could be possible but in district 4623 low potential local demand of biomass (only 14% of self-consumption) would provide higher distribution costs, so it will be advisable to install a power plant. In this district potential cogeneration sites have not been detected so it should be a power only plant.

In district 0326 and 0327 high number of potential cogeneration sites (11 and 7 respectivelly) makes this application highly promising. It is interesting to notice that, however the main part of benefits comes from electricity sold to the grid, cogeneration applications reduce payback period from 8.5 - 10 years (for power only application) to 6 - 7 years. As expected according to technology characterization, higher plant size increases economic feasibility.

11 For district 0326 and 0327, low average ash content (<3%) and high potential for self consumption of 12 biomass (74% and 68% respectively) make advisable the installation of a pellet plant. Specific investment 13 in district 0327 would be 13-15% lower than 0326 due to higher biomass plant size, and expected 14 payback period would be almost 10% shorter.

For biomass plants in the range 19 – 25 kt·year<sup>-1</sup> and transport distances of 13.5-23.3 km, it is observed that, from an economic point of view, cogeneration plant payback period is the shorter one (around 6.1 – 7 year), followed by pellet plants (6.5 - 7.2 years) and, in last position, the power-only plant with an expected payback period of around 8 - 10 years (for power plants in the range 3 - 5 MW).

Regarding CO<sub>2</sub> savings the magnitude is the same and it can be concluded that for cogenerations plants the CO<sub>2</sub> savings are 600 - 625 kg CO<sub>2</sub> ·t<sup>-1</sup> of biomass (with 35 - 40% moisture), a 15 - 20% higher than for pellet plant application and almost two times the CO<sub>2</sub> saving provided by a power-only power plant.

21 22 23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

#### 4. Conclusions

A methodology to optimize distributed biomass resources management and energy use has been developed, where logistics is a main factor but other features are also analyzed: biomass resources properties, plant size effect, CO<sub>2</sub> savings, economic feasibility, technologies costs, efficiency and restrictions, and potential biofuel consumers. This methodology provides quantification and characterization of biomass resources, a list of optimal locations from transport cost point of view, and basic economic, technical and CO<sub>2</sub> savings analysis of the different energy use options. The methodology is structured in different modules, and inside these modules there are many functions and constants that can be easily identified, modified or extended.

It has been observed that biomass compaction previous to transport reduces specific cost and CO<sub>2</sub> emissions of this operation, even for short distances. An analysis performed in Spain, for three districts of the Valencian community showed that biomass plant size and heat recovery, in cogeneration applications, increase the economic feasibility reducing payback periods in a 25 - 30%. Suitability for cogeneration applications can present big differences between areas under study because for these applications it is necessary to find a potential site for heat recovery (i.e. industry with high thermal needs). Cogeneration applications are, usually, optimal solutions from both CO<sub>2</sub> savings and economic feasibility point of view.

Pellet plant production becomes more feasible when most of the pellet production can be self-consumed in the area under study, in this case quantification of potential demand for pellets becomes an important

parameter for final decision. In the analysis performed in the Valencian community the potential pellet self-consumption can also vary very much from less than 20% to 100% according to local conditions.

234

5

6 7 8

9

1

#### Acknowledgements

This work was completed in the framework of the activities of the biomass research group of the the IIE (Instituto de Ingeniería Energética) in regional, national and international. The authors deeply thank all the organizations involved in these projects for their support and, specially, IMPIVA-Generalitat Valenciana, the Spanish Ministry of Science and Technology and the European Commission for the projects BIOVAL, BIODER and EU-DEEP respectively, for the provided funding that made this work possible.

10 11 12

13

14

#### References

- [1] Masera O., Ghilardi A., Drigo R., Trossero M.A. WISDOM: A GIS-based supply demand mapping tool for woodfuel management. Biomass and Bioenergy 2006; 30: 618-637
- 15 [2] Graham R. L., English B.C., Noon C. E. A Geographic Information System-based modeling system for evaluating the cost of delivered energy crop feedstock. Biomass and Bioenergy 2000;18: 309-329
- [3] Di Blasi C., Tanzi V., Lanzetta M. A study on the production of agricultural residues in Italy.
   Biomass and Bioenergy 1997;12: 321-331
- [4] Dias, J., Azevedo J.L.T. "Evaluation of biomass residual in Portugal mainland" Proceedings of the
   Conference on New and Renewable Energy Technologies for Sustainable Development, 24-26 June
   2002, Ponta Delgada, Azores, Portugal, pp. 215-228
- 22 [5] Voivontas D., Assimacopoulos D., Koukios E.G.. Assessment of biomass potential for power production: a GIS based method. Biomass and Bioenergy 2001;20:101-112
- EUBIONET (2003) "Biomass survey in Europe. Country report of Greece" European Bioenergy
   Network. European Energy Exchange. Available from: http://www.eubionet.net/ [accessed 05.09.07].
- [7] EUBIONET (2002) "Biomass survey in Europe. Country report of Spain-Andalusia" European
   Bioenergy Network. European Energy Exchange. Available from: <a href="http://www.eubionet.net/">http://www.eubionet.net/</a>.
   [accessed 05.09.07].
- 29 [8] "Phyllis, database for biomass and waste", http://www.ecn.nl/phyllis, Energy research Centre of the Netherlands [accessed 05.09.07].
- [9] DIRECTIVE 2002/91/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 16
   December 2002 on the energy performance of buildings. Official Journal of the European
   Communities. L 1/65.
- [10] Market assessment report on pellets in Southern Europe. Deliverable n.21, Sub-task 3.2.3, Work
   Phase 3.2. Project Pellets. for Europe, ALTENER 2002-012-137-160. Available from:
   www.pelletcentre.info [accessed 05.09.07]
- [11] Passalacqua F., Zaetta C., Janssen R., Pigaht M., Grassi G., Pastre O. et. al. Pellets in sourthern
   Europe. The state of the art of pellets utilization in southern Europe. New perspectives of pellets from
   agri-residues. 2nd World Conference on Biomass for Energy, Industry and Climate Protection, 10-14
   May 2004, Rome, Italy.
- 41 [12] Obernberger I., Thek G. "Wood pellet production costs under Austrian and in comparison to Swedish framework conditions", , Biomass and Bioenergy, 27 (2004) 671-693
- 43 [13] Minett S., Environmental Aspects of Cogeneration in Europe, Cogeneration & Onsite Power, Volume 2 Issue 6, Nov-Dec 2001.
- 45 [14] Wahlund B., Yan J., Westermark M. Increasing biomass utilisation in energy systems: A comparative study of CO2 reduction and cost for different bioenergy processing options. Biomass and Bioenergy 26 (2004) 531 544

[15] Peñalvo E., Alfonso D., Bogliolo L., Marra D., Bosio B., Pérez-Navarro A., Biomass energy valorisation plants based on MCFC for combined heat, power and biofuel production. 10th World Renewable Energy Congress, Florence (Italy),19-25 may 2006